## SIEMENS

## Data sheet

## 6GT2091-4LH20

product type designation product description

Cable RS422, Sub-D / M12

Highly flexible communication line (6-core)

SIMATIC RF, MV plug-in cable, pre-assembled, between RF120C and reader PUR, trailing, length 2 m.



suitability for use	Plug-in cable for connecting a reader to the RF120C communication module
cable designation	L-YC11Y 6x1x0.25 6x24AWG CM
wire length	2 m
electrical data	
number of electrical connections	2
type of electrical connection	Sub-D (male, 9 pin, 45°) / M12 (female, 8 pin, straight)
loop resistance per length / maximum	160 mΩ/m
insulation resistance coefficient	20 GΩ·m
operating voltage	
• maximum	300 V
mechanical data	
number of electrical cores	6
design of the shield	Braided shield made of tin-plated copper wires
outer diameter	
of cable sheath	5.4 mm
symmetrical tolerance of the outer diameter / of cable sheath	0.2 mm
material	
<ul> <li>of the wire insulation</li> </ul>	PVC
of cable sheath	PUR
color	
<ul> <li>of the insulation of data wires</li> </ul>	DIN 47100
of cable sheath	Black
bending radius	
<ul> <li>with single bend / minimum permissible</li> </ul>	21.6 mm
<ul> <li>with multiple bends / minimum permissible</li> </ul>	43 mm
<ul> <li>with continuous bending</li> </ul>	75 mm
number of bending cycles	300000
tensile load / maximum	200 N
weight per length	45 kg/km
ambient conditions	
ambient temperature	
during operation	-30 +80 °C
during storage	-30 +80 °C
during transport	-30 +80 °C
during installation	-30 +80 °C
fire behavior	flame resistant according to IEC 60332-1-2
class of burning behaviour / according to EN 13501-6	Eca
chemical resistance	

• to mineral oil	resistant
• to grease	resistant
radiological resistance / to UV radiation	resistant
product features, product functions, product components / gene	ral
product feature	
<ul> <li>halogen-free</li> </ul>	No
• silicon-free	Yes
standards, specifications, approvals	
UL/ETL listing / 300 V Rating	Yes; CM (only cable without plug)
certificate of suitability	
EAC approval	Yes
reference code	
according to IEC 81346-2	WG
according to IEC 81346-2:2019	WGB
further information / internet links	
internet link	
• to website: Selection guide for cables and connectors	https://support.industry.siemens.com/cs/ww/en/view/109766358
<ul> <li>to web page: selection aid TIA Selection Tool</li> <li>to website: Industrial communication</li> </ul>	https://www.siemens.com/tstcloud https://www.siemens.com/simatic-net
	https://www.siemens.com/
<ul> <li>to web page: SiePortal</li> <li>to website: Image database</li> </ul>	https://www.automation.siemens.com/bilddb
<ul> <li>to website: Image database</li> <li>to website: CAx-Download-Manager</li> </ul>	https://www.seuchration.stemens.com/biodo
to website: Industry Online Support	https://support.industry.siemens.com
security information	
Approvals / Certificates	In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic, state-of-the-art industrial cybersecurity concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial cybersecurity measures that may be implemented, please visit www.siemens.com/cybersecurity-industry. Siemens' product sand solutions undergo continuous development to make them more secure. Siemens strongly recommends that product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates, subscribe to the Siemens Industrial Cybersecurity RSS Feed under https://www.siemens.com/cert. (V4.7)
General Product Approval	
EMV Environment	
KC Confirmation	
last modified:	8/8/2024 🖸